

Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu

The Principal
Dewan Badri Nath (10+2) Vidya Mandir
Aarvilla, 155, Garden Avenue
Canal Road, Talab Tillo
Jammu

No: JDJF&ES/FPI/ 3523
Sub: Fire Safety Certificate.

Dated: 18.08.2020

Ref: Your's Letter No.DBNAV/SM/2020-21/126 dated: 04.06.2020.

Sir,

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed First Aid Fire Extinguishers in their school premises, besides underground water storage tank of 30 KL capacity. The school is about 05 Km away from Fire & Emergency Station City Jammu and is approachable for fire appliances in case of any emergency. As such, the management can proceed ahead for operation subject to adopt the following fire safety precautionary measures in letter and spirit forthwith:-

1. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
2. 01 No. of Clean Agent Type fire extinguisher of 02 Kg capacity should be provided in the Computer Lab. in addition to already existing fire extinguishers.
3. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling/operating of fire fighting system installed in the School building. The management shall intimate the office of Deputy Director, Fire & Emergency Services Command Jammu after each quarter that the fire fighting equipments installed in the school are functioning.
4. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
5. The corridor of the building shall not be used for any kind of storage.
6. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, the clearance will be treated withdrawn/cancelled.
7. One window of each class room should be without iron grill so that it can be used for safe evacuation of inmates during any mishap.
8. The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
9. At present school is double storied with basement. As such no addition/alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, the clearance will be treated withdrawn/cancelled.
10. Telephone numbers of nearest Fire & Emergency Stations should be displayed.
11. The validity of this clearance shall remain enforce for one year and same needs to be renewed after checking of fire fighting system installed in the school.

Manager
Dewan Badrinath Vidya Mandir Amarvillal (CBS)
Jammu

Yours Sincerely

[Signature]
Joint Director